

View Inc.
195 S. Milpitas Blvd
Milpitas, California 95035
United States

Dow Corning Construction Industry System General Test Laboratory Report - Sealant Compatibility

Date: 7/18/2016

Document ID:

Project Number: 16-006129

Project Name: GENERAL TEST View Inc

COMPATIBILITY TESTING (Modified ASTM C1087)

This letter summarizes the final results of the Compatibility testing of the Dow Corning Sealant as you requested.

Method Description: A ¼" bead of sealant is placed on either side of the supplied compound or substrate. Samples are allowed to cure 1 day at 50% +/- 5% RH and 23° ± 4° C (73 +/- 4 Deg F) and are then placed into an ultraviolet (UV) radiation chamber for 21 days for both direct and through glass exposure. After the exposure period is completed, the Dow Corning material is evaluated for tab adhesion and visual changes in its appearance caused by contact with the supplied compound or substrate.

General Test Guidelines: The attached test results performed as a "General Test" do not constitute an approval by Dow Corning for any Dow Corning Sealant application. The substrates provided, tests performed and test results were made at your request according to ASTM C1087. Dow Corning disclaims any responsibility and/or liability for use of failure test results in any project specific application as conditions and methods of use are beyond our control. The results of these tests are not sufficient to obtain a Dow Corning warranty on any current or future project. If a Dow Corning warranty is required or requested for an intended end use, additional samples and retesting must be performed by a Dow Corning test lab as outlined in the Americas Technical Manual.

DOW CORNING CORPORATION
Your Global Construction Connection @
www.dowcorning.com/construction

AMERICAS
Sealant Test Lab, DC-4, Lab 3A4
2200 W. Salzburg Road
Auburn, MI 48611
USA
Tel: 989 496 5237
Fax: 989 496 4374
Americas.Coins@dowcorning.com

ASIA
Songjiang Plant Dow Corning
(Shanghai) Company, Ltd.
448 Eastern Ave.
Songjiang Industrial Zone
Shanghai 201613, P. R. China
Phone: 86 21 5774 1161
Fax: 86 21 5774 3471
Asia.Coins@dowcorning.com

EUROPE
Parc de Seneffe Dow Corning
S.A.
Parc Industrie
7180 Seneffe
Belgium
Phone: 32 64 888 000
Fax: 32 0 64 88 8950
Europe.Coins@dowcorning.com

1. Sample Nr 86050	Substrate Details
Substrate Type	Tape
Substrate Description	3M 467MP 200MP Aluminum Face Black Tape
Surface to test	Face
Sealant	Application Recommendation
Dow Corning® 791 Silicone Weatherproofing Sealant	Found to be compatible in Weatherseal applications. (Please refer back to the General Test Guidelines-pg. 1)
Dow Corning® 795 Silicone Building Sealant	Found to be compatible. (Please refer back to the General Test Guidelines-pg. 1)

2. Sample Nr 86051	Substrate Details
Substrate Type	Tape
Substrate Description	3M 467MP 200MP Clear Tape
Surface to test	Face
Sealant	Application Recommendation
Dow Corning® 791 Silicone Weatherproofing Sealant	Found to be compatible in Weatherseal applications. (Please refer back to the General Test Guidelines-pg. 1)
Dow Corning® 795 Silicone Building Sealant	Found to be compatible. (Please refer back to the General Test Guidelines-pg. 1)

Application recommendations are based on Dow Corning laboratory testing, evaluation, and technical specifications.

The information contained herein is offered in good faith and is believed to be accurate. However, because conditions and methods of use of our products are beyond our control, this information should not be used in substitution for customer's tests to ensure that our products are safe, effective and fully satisfactory for the intended end use. Suggestions of use shall not be taken as inducements to infringe any patent.

Dow Corning's sole warranty is that our products will meet the sales specifications in effect at the time of the shipment.

Your exclusive remedy for breach of such warranty is limited to refund of purchase price or replacement of any product shown to be other than as warranted.

DOW CORNING CORPORATION
Your Global Construction Connection @
www.dowcorning.com/construction

AMERICAS
Sealant Test Lab, DC-4, Lab 3A4
2200 W. Salzburg Road
Auburn, MI 48611
USA
Tel: 989 496 5237
Fax: 989 496 4374
Americas.Coins@dowcorning.com

ASIA
Songjiang Plant Dow Corning
(Shanghai) Company, Ltd.
448 Eastern Ave.
Songjiang Industrial Zone
Shanghai 201613, P. R. China
Phone: 86 21 5774 1161
Fax: 86 21 5774 3471
Asia.Coins@dowcorning.com

EUROPE
Parc de Seneffe Dow Corning
S.A.
Parc Industrie
7180 Seneffe
Belgium
Phone: 32 64 888 000
Fax: 32 0 64 88 8950
Europe.Coins@dowcorning.com

Sincerely,



MATTHEW SCHAFKA
BUSINESS DEVELOPMENT PROFESSIONAL
415-971-6006

DOW CORNING CORPORATION

Americas Test Lab
Construction Industry
Fax: (989) 496-4374

DOW CORNING CORPORATION
Your Global Construction Connection @
www.dowcorning.com/construction

AMERICAS
Sealant Test Lab, DC-4, Lab 3A4
2200 W. Salzburg Road
Auburn, MI 48611
USA
Tel: 989 496 5237
Fax: 989 496 4374
Americas.Coins@dowcorning.com

ASIA
Songjiang Plant Dow Corning
(Shanghai) Company, Ltd.
448 Eastern Ave.
Songjiang Industrial Zone
Shanghai 201613, P. R. China
Phone: 86 21 5774 1161
Fax: 86 21 5774 3471
Asia.Coins@dowcorning.com

EUROPE
Parc de Seneffe Dow Corning
S.A.
Parc Industrie
7180 Seneffe
Belgium
Phone: 32 64 888 000
Fax: 32 0 64 88 8950
Europe.Coins@dowcorning.com